



**COUNTY OF FLUVANNA, VIRGINIA
(IFB) #2017-02
FIRE DETECTION & ALARM SYSTEMS**

ADDENDUM # 2:

Reference – Invitation for Bid:	IFB #2017-02
Title of Request for Proposal:	FIRE DETECTION & ALARM SYSTEMS
Issue Date:	December 9, 2016
Bid Due Date and Time:	January 5, 2016 at 2 p.m. EST

The above IFB #2017-02 is hereby amended and modified as follows:

1. The following are clarifications that amend and supplement Article 3, Scope of Work, of the IFB:
 - a. Regarding heat detectors in the garage bays: Provide the required number of heat detectors per the U.L. Listed spacing for the device proposed, and NFPA 72.
 - b. Regarding the sleeping rooms: Provide devices that meet the code requirements of sleeping areas in each fire station.
 - c. Regarding duct detectors: Determination will be made by the County after award and handled as a change to the scope if any are determined to be required.
 - d. "Regarding kitchens: Heat detection, rather than smoke, shall be furnished in each kitchen."
 - e. The basis of design in the solicitation and addenda constitutes a minimum requirement. Material, equipment, installation, and function shall meet Code.
 - f. Installation shall meet NFPA 70.

Signature page to follow:

Note: A signed acknowledgment of this addendum must be received at the location indicated on the RFP either prior to the bid due date and hour or attached to your bid. Signature on this addendum does not substitute for your signature on the original bid document. The original bid document must be signed. All inquiries, clarifications and additional information must be delivered in writing (via email) no later than December 22, 2016 by 11:00am and the responses will be provided in subsequent addendums.

Very truly yours,

Cyndi Toler, Purchasing Officer
Fluvanna County, Virginia
132 Main Street
Palmyra, VA 22963
(434) 591-1930

Name of Firm: _____

BY: _____

Signature of duly authorized representative

Title: _____

Date: _____